


ONE LINE DIAGRAM

NOTES:

- ALL COMPONENTS ARE UL LISTED
- ALL ENCLOSURES ARE OF CODE GA. ALUMINUM, TYPE 3R
- UNITS SHIP SEPARATELY FOR FIELD INSTALLATION
- MAIN DEVICES ARE SUITABLE FOR USE WITH COPPER OR ALUMINUM CONDUCTORS BASED ON AMPACITY AT 75°C
- THE SHORT CIRCUIT CURRENT RATING OF THIS ASSEMBLY IS 200,000 A.I.C.
- FUSES NOT PROVIDED

| | | | |
|-----------|---------------|---|----------|
| JOB: | | TITLE: 1600A METER CENTER 3PH 4W, 208Y/120V | |
| CUSTOMER: | | CONTRACTOR: | |
| REVISION | DWG. EM |  ELECTRICAL EQUIPMENT COMPANY ELK GROVE VILLAGE, ILLINOIS (847)-640-7701 MANUFACTURERS | S.O. |
| | CHK MM | | DWG. |
| | APP. | | 508-7BR2 |
| | DATE: 5/12/08 | | |
| | SCALE: | | |

SAMPLE DRAWING OF EQUIPMENT INSTALLED AROUND A CORNER BY USING A CORNER ELBOW